

District Level Water Testing Laboratory P.H.Division, Bettiah

# PUBLIC HEALTH DIVISION, BETTIAH

## CHEMICAL & BACTERIOLOGICAL EXAMINATION REPORT OF DRINKING WATER SAMPLES

SAMPLE COLLECTED ON 09/04/2025 BY Principal & RECEIVED IN THE LABORATORY ON 09/04/2025

Sl. NO	PARTICULARS OF THE SAMPLE				PARAMETERS EXAMINED (VALUE IN Mg/L except pH. Otherwise Mentioned)														
	Block	Gram Panchayat	Village/ Ward Number	Name of the Nearest person/Institution	Turbidity	pH	Conductivity	Total Hardness	Total Alkalinity	Calcium	Magnesium	Chloride	Sulphate	Iron	Nitrate	Flouride	T.D.S	Arsenic	Bacteriological test
1	Baitia	Bettiah Town.	Bettiah Town	Notre dame public school	1.0	7.3	421	172	176	40	14	23	15	0.2	0.0	0.2	281	NT	Neg
Min-Max Permissible Limit (IS:10500/2012)					1-5 NTU	6.5-8.5	-	200-600	200-600	75-200	30-100	250-1000	200-400	1.0-45 NR	45-45 NR	1-1.5	500-2000	0.01-0.05 NR	+VE -VE

Remarks-- Analysed parameters of above sample is within permissible limit

Signature of the Chemist  
**CHEMIST**  
**DLWTL**  
 P.H. Division, Bettiah.

## Annexure C

### PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 1346

Dated: 15/04/2025

It is certified that an inspection team headed by Manohar Prasad Sub Engineer from Siwan PHED inspected the **NOTRE DAME PUBLIC SCHOOL, BELBAGH, BETTIAH- 845438 ( BIHAR)** on 12/04/2025 (date of inspection) and on the basis of Water Test Report (Attached) bearing no 129/07 dated 12/04/2025 of Govt. Water Testing Lab, Bettiah (PHED Lab) certified that the **NOTRE DAME PUBLIC SCHOOL, BELBAGH, BETTIAH- 845438 ( BIHAR)** ( Name of school) has safe drinking water facilities for the students and members of staff of the institution. School is also maintains the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt. This certificate is valid till one year's 15/04/2025 to 14/10/2025

Signature with Seal : Anil Kr.  
15/04/2025  
Name : ANIL KUMAR **CHEMIST**  
**DLWTL**  
Designation : CHEMIST P.H. Division, Bettiah.

To  
The Principal  
NOTRE DAME PUBLIC SCHOOL  
BELBAGH, BETTIAH- 845438, WEST CHAMPARAN ( BIHAR )

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies